

Certificate of constancy of performance



0099/CPR/A43/0316

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n° 0099) has issued this certificate to

URSA IBÉRICA AISLANTES, S.A.

registered office	PO RECOLETOS, 3 28004 MADRID (España)
Construction Product	Mineral Wool for building equipment and industrial installations
Harmonized Standard	EN 14303:2009+A1:2013
Trade Mark	URSA AIR ZERO A2
	See annex for more information.
Production site	CR VILARRODONA, KM 6,7 43810 EL PLA DE SANTA MARIA (Tarragona - España)
Certification scheme	This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonized standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on	2012-06-21
Last issued	2016-11-28
Validity date	2017-11-28


AENOR Asociación Española de Normalización y Certificación

Avelino BRITO
Chief Executive Officer

AENOR Asociación Española de Normalización y Certificación

Génova, 6. 28004 Madrid. España
Tel. 902 102 201 - www.aenor.es

Certificate of constancy of performance

AENOR

0099/CPR/A43/0316

Annex to Certificate

Trade Mark URSA AIR ZERO A2

Range of thickness	Face A	Reaction to fire as placed on the market for face A	Face B	Reaction to fire as placed on the market for face B	Designation code	Mean Temperature(°C) / Thermal Conductivity (W/mK)
25 - 40	Aluminum + glass fiber tissue	A2-s1, d0	Glass fiber tissue + holt melt in black	A2-s1, d0	MW-EN 14303-T5-MV1	10 / 0,032 24 / 0,034 40 / 0,036 60 / 0,038

First issued on 2012-06-21
Last issued 2016-11-28
Validity date 2017-11-28

Original Electrónico

AENOR

Asociación Española de Normalización y Certificación

Génova, 6. 28004 Madrid. España
Tel. 902 102 201 – www.aenor.es