

# Certificate of constancy of performance



0099/CPR/A43/0315

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n° 0099) has issued this certificate to

## URSA IBÉRICA AISLANTES, S.A.

registered office PO RECOLETOS, 3 28004 MADRID (España)

Construction Product Mineral Wool for building equipment and industrial installations

Harmonized Standard EN 14303:2009+A1:2013

Trade Mark P8058 / URSA AIR TECH-2

See annex for more information.

Production site CR VILARRODONA, KM 6,7 43810 EL PLA DE SANTA MARIA (Tarragona - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonized standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2012-06-21  
Last issued 2016-11-28  
Validity date 2017-11-28

  
AENOR Asociación Española de Normalización y Certificación

Avelino BRITO  
Chief Executive Officer

**AENOR** Asociación Española de Normalización y Certificación

Génova, 6. 28004 Madrid. España  
Tel. 902 102 201 – www.aenor.es

# Certificate of constancy of performance

# AENOR

0099/CPR/A43/0315

## Annex to Certificate

Trade Mark P8058 / URSA AIR TECH-2

Range of thickness	Face A	Reaction to fire as placed on the market for face A	Face B	Reaction to fire as placed on the market for face B	Designation code	Mean Temperature(°C) / Thermal Conductivity (W/mK)
25	Aluminum + glass fiber tissue	A2-s1, d0	Pure aluminum reinforced	A2-s1, d0	MW-EN 14303-T5-MV1	10 / 0,032 24 / 0,034 40 / 0,036 60 / 0,038

First issued on 2012-06-21  
Last issued 2016-11-28  
Validity date 2017-11-28

Original Electrónico

**AENOR**

Asociación Española de  
Normalización y Certificación

Génova, 6. 28004 Madrid. España  
Tel. 902 102 201 – www.aenor.es